

Larkspur Elementary School

- 27 total drinking water fixtures tested
- 24 water fixtures resulted less than 15 ppb
- 2 fixtures required validation testing and resulted in less than 15 ppb
- Replacement/Removal of 1 water fixture occurred
 - A fixture in room 24 was replaced and retested
- Following Replacement/Removal, all results less than 15 ppb – no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date	Validation Result (ppb)	2nd Collection Date	Clearance Result (ppb)	3rd Collection Date
Larkspur ES	180310001-305 Lobby Bottle Filler	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-306 Lobby Upper Fountain	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-307 Lobby Lower Fountain	0.7	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-308 Room 21 Sink	6.9	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-309 Room 20 Sink	7.1	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-310 Room 34 Sink	13.0	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-311 Room 35 Upper Sink	0.7	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-312 Room 35 Lower Sink	1.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-313 Room 52 Sink	7.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-314 Room 50 Sink	0.9	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-315 Room 49 Sink	2.2	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-316 Room 47 Sink	1.6	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-317 Room 46 Sink	0.6	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-318 Room 44 Sink	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-319 Fountain by Room 40	1.0	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-320 Room 41 Sink	16.0	3/17/2018	10.1	4/21/2018	N/A	N/A
Larkspur ES	180310001-321 Room 27 Sink	11.0	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-322 Room 26 Sink	27.0	3/17/2018	14	4/21/2018	N/A	N/A
Larkspur ES	180310001-323 Room 24 Sink	24.0	3/17/2018	25	4/21/2018	3	6/4/2018
Larkspur ES	180310001-324 Break Room Sink	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-325 Room 13 Sink	4.4	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-326 Room 13 Fountain	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-327 Gym/Cafeteria Fountain	0.6	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-328 Kitchen #1	2.2	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-329 Kitchen #2	1.1	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-330 Kitchen #3	0.5	3/17/2018	N/A	N/A	N/A	N/A
Larkspur ES	180310001-331 Kitchen #4	2.6	3/17/2018	N/A	N/A	N/A	N/A

