- 127 total drinking water fixtures tested
- 122 water fixtures resulted less than 15 ppb
- 1 fixture required validation testing and resulted in less than 15 ppb
- Replacement/Removal of 4 water fixtures occurred
 - o Specific fixtures in rooms 2225, 2230, 2290 and 2440 were replaced and retested
- Following Replacement/Removal, all results less than 15 ppb no further action needed

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
		(ppb)	Date	(ppb)	Date	(ppb)	Date
Highlands Ranch HS	HR 115 Counseling Sink	0.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 116 Auditorium Fountain	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 117 Fountain at Bottom Ramp	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 118 Fountain in 500N	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 119 Fountain in 600N	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 120 Fountain in 400N	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 121 Rm 404 Sink	0.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 122 Rm 402 Sink	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 123 Rm 300N Sink	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 124 Upper Fountain in LRs	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 125 Lower Fountain in LRs	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 126 Sports Medicine Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 127 890 Fountain	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 128 870 Bottle Filler	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 129 870 Fountain	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 130 Kitchen 1st Sink	1.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 131 Kitchen 2nd Sink	0.6	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 132 Kitchen 3rd Sink	1.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 133 Kitchen 4th Sink	3.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 134 Kitchen 5th Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 135 Kitchen 6th Sink	0.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 136 Rm 1203 W	0.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 137 Bottle Filler Across From 1207W	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 138 Upper Fountain Across from 1207W	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 139 Lower Fountain Across from 1207W	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 140 1230 W Lounge Sink	0.4	3/10/2018	N/A	N/A	N/A	N/A

Cito	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
Site	Sample ID	(ppb)	Date	(ppb)	Date	(ppb)	Date
Highlands Ranch HS	HR 141 Bottle Filler by West Entrance	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 142 Fountain by West Entrance	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 143 Upper Fountain Next to 1604E	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 144 Lower Fountain Next to 1604E	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 145 1620 E Lounge Sink	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 146 1650E Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 147 1190 E Sink	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 148 1170 Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 149 1140 Sink	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 150 Health Room Sink	0.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 151 111 E Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 152 Library Upper Fountain	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 153 Library Lower Fountain	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 154 1480 Sink	3.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 155 2225 1st Sink	5.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 156 2225 2nd Sink	12.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 157 2225 3rd Sink	14.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 158 2225 4th Sink	18.1	3/10/2018	21	3/28/2018	7.5	4/28/2018
Highlands Ranch HS	HR 159 2225 5th Sink	13.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 160 2225 6th Sink	13.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 161 2225 7th Sink	12.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 162 2235 1st Sink	3.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 163 2235 2nd Sink	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 164 2235 3rd Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 165 2235 4th Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 166 2235 5th Sink	0.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 167 2235 Prep Sink	1.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 168 2245 1st Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 169 2245 2nd Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 170 2245 3rd Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 171 2245 4th Sink	0.6	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 172 2245 5th Sink	0.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 173 2245 Prep Sink	1.6	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 174 2275 1st Sink	19.6	3/10/2018	7.1	3/28/2018	N/A	N/A
Highlands Ranch HS	HR 175 2275 2nd Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 176 2275 3rd Sink	0.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 177 2275 4th Sink	4.3	3/10/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
		(ppb)	Date	(ppb)	Date	(ppb)	Date
Highlands Ranch HS	HR 178 2275 5th Sink	3.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 179 2290 1st Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 180 2290 2nd Sink	1.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 181 2290 3rd Sink	1.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 182 2290 4th Sink	1.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 183 2290 5th Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 184 2290 6th Sink	4.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 185 2290 Prep Sink	108.2	3/10/2018	53	3/28/2018	6.3	4/28/2018
Highlands Ranch HS	HR 186 2305 Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 187 2320 Lounge Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 188 2360 1st Sink	1.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 189 2360 2nd Sink	1.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 190 2360 3rd Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 191 2360 4th Sink	1.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 192 2360 5th Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 193 2360 6th Sink	3.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 194 2360 7th Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 195 2360 8th Sink	1.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 196 2360 9th Sink	5.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 197 2343 Sink	8.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 198 2344 1st Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 199 2344 2nd Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 200 2210 1st Sink	2.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 201 2210 2nd Sink	0.6	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 202 2210 3rd Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 203 2210 4th Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 204 2210 5th Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 205 2210 6th Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 206 2210 7th Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 207 2210 8th Sink	2.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 208 2230 1st Sink	6.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 209 2230 2nd Sink	12.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 210 2230 3rd Sink	13.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 211 2230 4th Sink	20.6	3/10/2018	37	3/28/2018	8.3	4/28/2018
Highlands Ranch HS	HR 212 2230 5th Sink	10.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 213 2230 6th Sink	13.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 214 2230 7th Sink	14.9	3/10/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
Site	Sample 15	(ppb)	Date	(ppb)	Date	(ppb)	Date
Highlands Ranch HS	HR 215 2230 8th Sink	10.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 216 Fountain Across from 2420	0.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 217 Bottle Filler next to 2604	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 218 Upper Fountain Next to 2604	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 219 Lower Fountain Next to 2604	0.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 220 2635 Sink	1.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 221 2440 1st Sink	1.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 222 2440 2nd Sink	28.5	3/10/2018	20	3/28/2018	10	4/28/2018
Highlands Ranch HS	HR 223 2440 3rd Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 224 2440 4th Sink	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 225 2440 5th Sink	2.1	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 226 2440 Prep Room Sink	8.4	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 227 2420 1st Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 228 2420 2nd Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 229 2420 3rd Sink	1.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 230 2420 4th Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 231 2420 5th Sink	8.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 232 2460 1st Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 233 2460 2nd Sink	1.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 234 2460 3rd Sink	1.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 235 2460 4th Sink	1.0	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 237 2460 Prep room Sink	7.3	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 238 2150 Sink	1.9	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 239 Fountain Next to Art Dept.	0.5	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 240 2010 Sink	0.8	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 241 Fountain Across from Gym Upstairs	0.2	3/10/2018	N/A	N/A	N/A	N/A
Highlands Ranch HS	HR 242 2060 Sink	0.7	3/10/2018	N/A	N/A	N/A	N/A