- 160 total drinking water fixtures tested
- 149 water fixtures resulted less than 15 ppb
- 5 fixtures required validation testing and resulted in less than 15 ppb
- Replacement/Removal of 6 water fixtures occurred
 - o A fixture in room 62 Prep was removed
 - o Specific fixtures in rooms 36 Prep, 60, 61, and 62 were replaced and retested
- Following Replacement/Removal, all results less than 15 ppb no further action needed

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
		(ppb)	Date	(ppb)	Date	(ppb)	Date
Douglas County HS	CR091 Kitchen S 1st	3.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR092 Kitchen S 2nd	14.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR093 1045 DF Hall	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR094 1045 Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR095 105 S Sink	6.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR096 N. Upstairs Hall Athletic Office DF	8.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR097 Atrium S 1st Bottle	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR098 Atrium S 2nd DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR099 Country Cheer DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR100 62 S Sink	1.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR101 N. Upstairs Hall Outside 66S DF	2.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR102 66S Sink	2.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR103 Foreign Language Office Sink	0.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR104 70S Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR105 77S Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR106 Custodial Closet DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR107 13 S 1st Sink	1.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR108 13 S 2nd Sink	1.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR109 13 S 3rd Sink	1.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR110 13 S 4th Sink	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR111 13 S 5th Sink	1.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR112 13 S 6th Sink	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR113 12 S 1st Sink	0.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR114 12 S 2nd Sink	1.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR115 12 S 3rd Sink	1.1	3/19/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
Site	·	(ppb)	Date	(ppb)	Date	(ppb)	Date
Douglas County HS	CR116 12 S 4th Sink	9.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR117 12 S 5th Sink	3.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR118 Science Prep Room Sink	1.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR119 11S 1st Sink	1.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR120 11S 2nd Sink	2.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR121 11S 3rd Sink	3.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR122 11 S 4th Sink	1.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR123 11 S 5th Sink	2.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR124 11 S 6th Sink	1.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR125 Main Hall 1st South Bottle	0.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR126 Main Hall 2nd South DF	0.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR127 10 S 1st Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR128 10 S 2nd Sink	0.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR129 Main Office Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR130 Teachers' Lounge Sink	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR131 Main Office South Sink	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR132 3 S 1st Sink	5.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR133 3 S 2nd Sink	0.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR134 2 S Sink	0.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR135 Outside Cafeteria 1st DF	9.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR136 Outside Cafeteria 2nd DF	4.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR137 N Kitchen 2nd Sink	2.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR138 N Kitchen 1st Sink	3.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR139 N Kitchen 3rd Sink	2.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR140 N Kitchen 4th Sink	5.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR141 N. Kitchen 5th Sink	22.8	3/19/2018	1.4	4/6/2018	N/A	N/A
Douglas County HS	CR142 N. Kitchen 6th Sink	1.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR143 N Kitchen 7th Sink	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR144 N Kitchen 8th Sink	3.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR145 Serving Line Sink	11.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR146 Subway Sink	2.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR147 Teachers' Lounge N Sink	0.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR148 Across Main Office DF	0.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR149 Across Main Office 1st Bottle	0.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR150 Across Main Office 2nd DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR151 Main Office 1st DF	0.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR152 Main Office 2nd Sink	1.5	3/19/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
		(ppb)	Date	(ppb)	Date	(ppb)	Date
Douglas County HS	CR153 Main Office 3rd Sink	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR154 Rm 1 1st Sink	1.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR155 Rm 1 2nd Sink	1.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR156 Rm 1 3rd Sink	1.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR157 Rm 1 4th Sink	1.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR158 Rm 5th Sink	1.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR159 Rm 1 6th Sink	1.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR160 Rm 3 Sink	3.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR161 Rm 5 Sink	2.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR162 Rm 6 DF Piano	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR163 Hall Next to Rm 30 DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR164 Theatre Office Sink	5.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR165 Middle Hall Eng. Office DF	2.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR166 Rm 36 1st Sink	4.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR167 Rm 36 2nd Sink	6.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR168 Rm 36 3rd Sink	7.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR169 Rm 36 4th Sink	4.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR170 Rm 36 5th Sink	8.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR171 Rm 36 6th Sink	20.3	3/19/2018	5.6	4/6/2018	N/A	N/A
Douglas County HS	CR172 Rm 36 7th Sink	6.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR173 Rm36 Prep Rm Sink	20.2	3/19/2018	37.6	4/6/2018	2.9	6/11/2018
Douglas County HS	CR174 Rm37 1st Sink	4.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR175 Rm 37 2nd Sink	4.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR176 Rm37 3rd Sink	3.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR177 Rm37 4th Sink	16.7	3/19/2018	5.6	4/6/2018	N/A	N/A
Douglas County HS	CR178 Rm37 5th Sink	7.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR179 Rm 37 6th Sink	91.1	3/19/2018	9.2	4/6/2018	N/A	N/A
Douglas County HS	CR180 Rm37 7th Sink	12.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR181 Rm 46 1st Sink	7.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR182 Rm 46 2nd Sink	6.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR183 Arts Hallway 1st DF	1.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR184 Arts Hallway 2nd DF	0.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR185 Rm 53 1st Sink	5.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR186 Rm53 2nd Sink	4.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR187 Rm60 1st Sink	5.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR188 Rm 60 2nd Sink	2.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR189 Rm 61 1st Sink	10.8	3/19/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
		(ppb)	Date	(ppb)	Date	(ppb)	Date
Douglas County HS	CR190 Rm 61 2nd Sink	5.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR191 Rm 61 3rd Sink	6.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR192 62 Sink Prep	17.1	3/19/2018	20.1	4/6/2018	removed sink	6/11/2018
Douglas County HS	CR193 Rm 62 1st Sink	7.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR194 Rm 62 2nd Sink	18.0	3/19/2018	15.6	4/6/2018	2.6	6/11/2018
Douglas County HS	CR195 Rm 62 3rd Sink	2.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR196 Rm 63 1st Sink	1.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR197 Rm 63 2nd Sink	5.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR198 Rm 63 3rd Sink	10.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR199 Rm 63 4th Sink	4.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR200 Rm 63 5th Sink	1.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR201 Rm 63 6th Sink	2.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR202 Hall Next to Rm 65 DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR203 Rm 65 1st Sink	6.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR204 Rm 65 2nd Sink	2.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR205 Rm 65 3rd Sink	3.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR206 Rm 65 4th Sink	5.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR207 Rm 65 5th Sink	10.3	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR208 Rm 65 6th Sink	5.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR209 Rm 65 7th Sink	6.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR210 Rm 65 Prep Rm Sink	3.9	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR211 Hallway Sprinkler Control DF	2.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR212 Hallway Sprinkler Girls Bottle	0.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR213 Hallway Sprinkler Girls DF	0.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR214 Library Media Staff Sink	0.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR215 Lower Horseshoe 1st DF	4.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR216 Lower Horseshoe 2nd DF	3.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR217 Lower Horseshoe 3rd DF	1.7	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR218 Outside F115 1st DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR219 Outside f115 2nd DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR220 F114 DF	0.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR221 F113 1st Sink	0.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR222 F113 2nd Sink	1.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR223 Outside F112 1st DF	0.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR224 F112 2nd Bottle	0.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR225 Outside F112 3rd DF	0.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR226 Outside F109 1st DF	0.2	3/19/2018	N/A	N/A	N/A	N/A

Site	Sample ID	Initial Result	1st Collection	Validation Result	2nd Collection	Clearance Result	3rd Collection
Site	Sample 10	(ppb)	Date	(ppb)	Date	(ppb)	Date
Douglas County HS	CR227 Outside F109 2nd DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR228 F101 DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR229 F102 Sink	0.8	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR230 Horseshoe Upper DF	5.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR231 Horseshoe Upper DF	1.4	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR232 Horseshoe Upper DF	6.5	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR233 Teachers' Lounge Upper Sink	1.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR234 Locker Room Hallway Gym DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR235 Locker Rm Hallway Gym DF	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR236 Rm 17 Sink	1.0	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR237 Rm 16 Kitchen Sink	0.2	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR238 Copy Room Sink	2.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR239 Rm 12 Sink	6.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR240 N Gym Hall DF	0.1	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR241 N Gym DF	3.6	3/19/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR256 Room 62 X1 Sink	7.6	4/14/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR257 Room 62 X2 Sink	15.8	4/14/2018	14.7	4/27/2018	N/A	N/A
Douglas County HS	CR258 Room 62 X3 Sink	10.4	4/14/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR259 Room 62 X4 Sink	13.5	4/14/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR260 Room 62 X5 Sink	1.3	4/14/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR261 Room 61 X1 Sink	19.2	4/14/2018	16.6	4/27/2018	3.3	6/11/2018
Douglas County HS	CR262 Room 61 X2 Sink	6.6	4/14/2018	N/A	N/A	N/A	N/A
Douglas County HS	CR263 Room 61 X3 Sink	17.9	4/14/2018	16.4	4/27/2018	1.4	6/11/2018
Douglas County HS	CR264 Room 60 X1 Sink	30.9	4/14/2018	38.1	4/27/2018	1.7	6/11/2018