

Pine Lane Primary

- 60 total drinking water fixtures tested
- 58 water fixtures resulted less than 15 ppb
- 1 fixture required validation testing and resulted in less than 15 ppb
- Replacement/Removal of 1 water fixture occurred
 - A fixture in the office conference room was removed
- Following Replacement/Removal, all results less than 15 ppb – no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date	Validation Result (ppb)	2nd Collection Date	Clearance Result (ppb)	3rd Collection Date
Pine Lane Primary	Cafeteria Bottle Filler	0.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Cafeteria Fountain	0.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Hall Sink by room 309 Lower	1.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Hall Sink by Room 309 Upper	1.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Kitchen Sink #1	2.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Kitchen Sink #2	5.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Kitchen Sink #3	5.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Library Workroom Sink	19.0	4/28/2018	7	5/19/2018	N/A	N/A
Pine Lane Primary	Lower Fountain by Room 515	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Lower Sink by 512	0.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Office Break Room	45.3	4/28/2018	25.5	5/19/2018	removed sink	6/11/2018
Pine Lane Primary	Room 101 Fountain	0.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 101 Sink	7.0	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 102 Fountain	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 102 Sink	2.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 103 Fountain	0.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 103 Sink	2.0	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 104 Fountain	0.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 104 Sink	2.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 105 Fountain	0.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 105 Sink	3.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 106 Fountain	1.8	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 106 Sink	2.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 201 Fountain	0.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 201 Sink	2.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 202 Fountain	0.6	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 202 Sink	2.5	4/28/2018	N/A	N/A	N/A	N/A

Pine Lane Primary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date	Validation Result (ppb)	2nd Collection Date	Clearance Result (ppb)	3rd Collection Date
Pine Lane Primary	Room 203 Fountain	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 203 Sink	2.5	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 204 Fountain	0.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 204 Sink	3.0	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 205 Fountain	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 205 Sink	1.8	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 206 Fountain	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 206 Sink	1.4	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 301 Fountain	1.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 301 Sink	4.0	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 302 Fountain	0.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 302 Sink	3.1	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 303 Fountain	0.5	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 303 Sink	2.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 304 Fountain	0.5	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 304 Sink	2.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 305 Fountain	1.0	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 305 Sink	3.9	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 306 Fountain	1.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 306 Sink	2.1	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 309 Fountain	5.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 309 Sink	12.6	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 401 Sink	0.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 402 Sink	0.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 403 Fountain	0.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 403 Sink	1.1	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 404 Fountain	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 404 Sink	1.8	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 515 Fountain	9.7	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Room 515 Sink	6.5	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Staff Lounge	1.2	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Upper Fountain by Room 515	0.3	4/28/2018	N/A	N/A	N/A	N/A
Pine Lane Primary	Upper Sink by 512	0.0	4/28/2018	N/A	N/A	N/A	N/A