

Cherokee Trail Elementary

- 40 total drinking water fixtures tested
- 39 water fixtures resulted less than 15 ppb
- Replacement/Removal of 1 water fixtures occurred
 - A fixture in room 111 was removed
- Following Replacement/Removal, all results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date	Validation Result (ppb)	2nd Collection Date	Clearance Result (ppb)	3rd Collection Date
Cherokee Trail ES	Fountain by Room 110	0.8	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Fountain by Room 124	0.2	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Fountain by Room 164	1.2	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Fountain by Room 217A	1.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Fountain by Room 233A	1.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Kitchen Sink # 1	1.7	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Kitchen Sink #2	4.6	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Kitchen Sink #3	1.7	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Kitchen Sink #4	3.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Lobby Bottle Filler	0.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Lobby Lower Sink	0.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Lobby Upper Sink	0.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 111 Sink	16.8	4/28/2018	32.48	5/19/2018	removed sink	6/11/2018
Cherokee Trail ES	Room 113 Sink	1.3	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 145 Sink	2.7	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 146 Sink	3.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 158 Sink	3.0	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 159 Sink	1.0	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 160 Sink	1.4	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 161 Sink	2.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 162 Sink	3.0	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 163 Sink	2.3	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 164 Sink	1.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 185 Sink	0.8	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 190 Sink	0.2	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 202 Sink	2.9	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 203 Sink	1.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 204 Sink	1.5	4/28/2018	N/A	N/A	N/A	N/A

Cherokee Trail Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date	Validation Result (ppb)	2nd Collection Date	Clearance Result (ppb)	3rd Collection Date
Cherokee Trail ES	Room 205 Sink	1.8	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 206 Sink	2.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 207 Sink	3.0	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 208 Sink	1.6	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 209 Sink	3.5	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 211 Sink	7.4	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 222 Sink	1.7	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 223 Sink	1.7	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 224 Sink	1.8	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 225 Sink	13.2	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 226 Sink	6.1	4/28/2018	N/A	N/A	N/A	N/A
Cherokee Trail ES	Room 227 Sink	2.2	4/28/2018	N/A	N/A	N/A	N/A