

**Eldorado Elementary School**

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Eldorado Elementary School	HR108 Kitchen 2nd Sink	4.9	2/24/2018
Eldorado Elementary School	HR107 Gym Fountain	0.5	2/24/2018
Eldorado Elementary School	HR109 Rm 379 Sink	0.4	2/24/2018
Eldorado Elementary School	HR106 Bottle Filler by Office	0.2	2/24/2018