

Redstone Elementary School

- **7 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Redstone Elementary School	HR041 Kitchen 4th Sink	2.0	2/24/2018
Redstone Elementary School	HR043 V13 Sink	0.8	2/24/2018
Redstone Elementary School	HR044 M15 Sink	0.5	2/24/2018
Redstone Elementary School	HR046 M27 Sink	0.5	2/24/2018
Redstone Elementary School	HR042 Rm L15 Sink	0.3	2/24/2018
Redstone Elementary School	HR040 Lower Drinking Fountain in Gym	0.2	2/24/2018
Redstone Elementary School	HR045 Fountain to the Left of M07	0.1	2/24/2018