## Clear Sky Elementary School

## Clear Sky Elementary School

- 6 drinking water fixtures tested
- All results less than 15 ppb no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Clear Sky Elementary School	CR041 B102 Sink	1.9	3/3/2018
Clear Sky Elementary School	CR038 Kicthen 5th Sink	1.5	3/3/2018
Clear Sky Elementary School	CR036 A110 Bubbler	1.3	3/3/2018
Clear Sky Elementary School	CR039 B221 Sink	1.1	3/3/2018
Clear Sky Elementary School	CR040 B228 Sink	0.5	3/3/2018
Clear Sky Elementary School	CR037 Fountain in Gym	0.3	3/3/2018