

Chaparral High School

- 9 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Chaparral High School	Kitchen Sink (C3)	10.7	4/10/2018
Chaparral High School	Room 413-1 (C6)	3.6	4/10/2018
Chaparral High School	Room L416-1 (C5)	2.6	4/10/2018
Chaparral High School	Room L520 (C4)	1.7	4/10/2018
Chaparral High School	Room 322-1 (C8)	0.6	4/10/2018
Chaparral High School	Bottle Filler Lobby (C1)	0.2	4/10/2018
Chaparral High School	Room 200 Hallway (C9)	0.2	4/10/2018
Chaparral High School	Athletic Hallway (C2)	0.1	4/10/2018
Chaparral High School	Hallway U425 (C7)	0.1	4/10/2018