

**West Transportation Bldg. C**

- 1 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
West Transportation Bldg C	CR052 Water Fountain	0.7	3/3/2018