

**Timber Trail Elementary School**

- **5 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Timber Trail Elementary School	180210001-115 Kitchen First Hand Sink	3.2	2/10/2018
Timber Trail Elementary School	180210001-116 U14 Sink	1.8	2/10/2018
Timber Trail Elementary School	180210001-117 Room L 13 Sink	1.2	2/10/2018
Timber Trail Elementary School	180210001-118 Room M13 Sink	0.8	2/10/2018
Timber Trail Elementary School	180210001-114 Hall Drinking Fountain by Music M58	0.5	2/10/2018