

Thunder Ridge High School

- 11 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Thunder Ridge High School	HR023 Kitchen 3rd Sink	6.8	2/24/2018
Thunder Ridge High School	HR030 MO218 Sink	1.9	2/24/2018
Thunder Ridge High School	HR031 L2004 Sink	1.9	2/24/2018
Thunder Ridge High School	HR029 D209A Sink	1.8	2/24/2018
Thunder Ridge High School	HR027 E218 Sink	1.2	2/24/2018
Thunder Ridge High School	HR022 B120 Sink (Warm)	0.9	2/24/2018
Thunder Ridge High School	HR025 Fountain in Athletic Hallway	0.7	2/24/2018
Thunder Ridge High School	HR026 E102 2nd Sink	0.4	2/24/2018
Thunder Ridge High School	HR028 F202 3rd Sink	0.3	2/24/2018
Thunder Ridge High School	HR021 Bottle Filler Across from Auditorium	0.2	2/24/2018
Thunder Ridge High School	HR024 Lower Fountain Next to Maint. Hallway	0.1	2/24/2018