

Teddy Lane Center

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Teddy Lane Center	180310001-215 Bridge 101A Bathroom, Lower Fountain	1.0	3/17/2018
Teddy Lane Center	180310001-216 Break Rm 108, Kitchen Sink	1.0	3/17/2018
Teddy Lane Center	180310001-217 Fountain by 120, Lower Fountain	1.0	3/17/2018