

Summit View Elementary School

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Summit View Elementary School	HR076 Rm 223 Sink	6.9	2/24/2018
Summit View Elementary School	HR075 Kitchen 3rd Sink	1.0	2/24/2018
Summit View Elementary School	HR074 Upper Fountain by Gym	0.2	2/24/2018