

Soaring Hawk Elementary School

- **5 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Soaring Hawk Elementary School	CR032 Kitchen 4th Sink	5.2	3/3/2018
Soaring Hawk Elementary School	CR035 M16 Sink	1.5	3/3/2018
Soaring Hawk Elementary School	CR033 U15 Sink	0.5	3/3/2018
Soaring Hawk Elementary School	CR034 Fountain to the Right of L07	0.2	3/3/2018
Soaring Hawk Elementary School	CR031 Fountain Next to M58	0.1	3/3/2018