

**Sand Creek Elementary School**

- **41 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Sand Creek Elementary School	HR 275 164 Bubblers	11.0	3/10/2018
Sand Creek Elementary School	HR 251 Kitchen 2nd Sink	7.4	3/10/2018
Sand Creek Elementary School	HR 274 164 Sink	6.1	3/10/2018
Sand Creek Elementary School	HR 269 145 Sink	5.7	3/10/2018
Sand Creek Elementary School	HR 277 165 Bubblers	3.8	3/10/2018
Sand Creek Elementary School	HR 253 Kitchen 4th Sink	3.3	3/10/2018
Sand Creek Elementary School	HR 279 167 Bubblers	2.7	3/10/2018
Sand Creek Elementary School	HR 276 165 Sink	2.1	3/10/2018
Sand Creek Elementary School	HR 282 159 Sink	2.1	3/10/2018
Sand Creek Elementary School	HR 252 Kitchen 3rd Sink	1.6	3/10/2018
Sand Creek Elementary School	HR 262 203 Sink	1.6	3/10/2018
Sand Creek Elementary School	HR 249 Café Sink	1.4	3/10/2018
Sand Creek Elementary School	HR 250 Kitchen 1st Sink	1.4	3/10/2018
Sand Creek Elementary School	HR 263 203 Sink	1.3	3/10/2018

Sand Creek Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Sand Creek Elementary School	HR 268 146 Sink	1.2	3/10/2018
Sand Creek Elementary School	HR 281 160 Sink	1.2	3/10/2018
Sand Creek Elementary School	HR 283 158 Sink	1.2	3/10/2018
Sand Creek Elementary School	HR 280 Fountain Next to 176	1.0	3/10/2018
Sand Creek Elementary School	HR 265 205 Sink	0.8	3/10/2018
Sand Creek Elementary School	HR 266 206 Sink	0.8	3/10/2018
Sand Creek Elementary School	HR 270 153 Sink	0.8	3/10/2018
Sand Creek Elementary School	HR 273 161 Sink	0.8	3/10/2018
Sand Creek Elementary School	HR 258 Fountain next to 235	0.7	3/10/2018
Sand Creek Elementary School	HR 261 227 Sink	0.7	3/10/2018
Sand Creek Elementary School	HR 264 204 Sink	0.7	3/10/2018
Sand Creek Elementary School	HR 272 162 Sink	0.7	3/10/2018
Sand Creek Elementary School	HR 254 Staff Lounge Sink	0.6	3/10/2018
Sand Creek Elementary School	HR 255 222 Sink	0.6	3/10/2018
Sand Creek Elementary School	HR 257 224 Sink	0.6	3/10/2018
Sand Creek Elementary School	HR 260 226	0.6	3/10/2018
Sand Creek Elementary School	HR 278 167 Sink	0.6	3/10/2018

Sand Creek Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Sand Creek Elementary School	HR 256 223 Sink	0.5	3/10/2018
Sand Creek Elementary School	HR 259 225 Sink	0.5	3/10/2018
Sand Creek Elementary School	HR 244 138 Sink	0.4	3/10/2018
Sand Creek Elementary School	HR 267 207 Sink	0.4	3/10/2018
Sand Creek Elementary School	HR 341 Mobile 15 Sink	0.4	3/10/2018
Sand Creek Elementary School	HR 245 Upper Fountain in Gym	0.3	3/10/2018
Sand Creek Elementary School	HR 246 Lower Fountain in Gym	0.3	3/10/2018
Sand Creek Elementary School	HR 271 163 Sink	0.3	3/10/2018
Sand Creek Elementary School	HR 247 Bottle Filler Outside 120	0.2	3/10/2018
Sand Creek Elementary School	HR 248 Fountain Outside 120	0.2	3/10/2018