

Lone Tree Elementary School

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Lone Tree Elementary School	180310001-218 Lobby Fountain	1.0	3/17/2018
Lone Tree Elementary School	180310001-219 M14 Sink	1.0	3/17/2018
Lone Tree Elementary School	180310001-220 U13 Sink	1.0	3/17/2018
Lone Tree Elementary School	180310001-221 Kitchen 1st Sink	1.0	3/17/2018