

**Legacy Point Elementary School**

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Legacy Point Elementary School	U16 Sink	6.7	4/28/2018
Legacy Point Elementary School	Kitchen 2nd Sink	2.3	4/28/2018
Legacy Point Elementary School	M13 Sink	1.0	4/28/2018
Legacy Point Elementary School	Fountain by M58	0.2	4/28/2018