

**Heritage Elementary School**

- **5 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Heritage Elementary School	HR071 Kitchen 2nd Sink	1.5	2/24/2018
Heritage Elementary School	HR072 Rm 279 Sink	0.5	2/24/2018
Heritage Elementary School	HR069 Bottle Filler Next to Office	0.2	2/24/2018
Heritage Elementary School	HR070 Gym Water Fountain	0.2	2/24/2018
Heritage Elementary School	HR073 Fountain Across from 379	0.2	2/24/2018