

Gold Rush Elementary School

- **7 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Gold Rush Elementary School	Kitchen 3rd Sink	1.9	4/28/2018
Gold Rush Elementary School	B225 Sink	0.8	4/28/2018
Gold Rush Elementary School	B108 Sink	0.8	4/28/2018
Gold Rush Elementary School	B125 Sink	0.6	4/28/2018
Gold Rush Elementary School	A110 Fountain	0.5	4/28/2018
Gold Rush Elementary School	Gym Fountain	0.3	4/28/2018
Gold Rush Elementary School	Fountain by B224 Upper	0.2	4/28/2018