

Frontier Valley Elementary School

- **5 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Frontier Valley Elementary School	Kitchen Sink #1	1.5	4/28/2018
Frontier Valley Elementary School	Room 178 Sink	1.1	4/28/2018
Frontier Valley Elementary School	Room 277 Sink	1.0	4/28/2018
Frontier Valley Elementary School	Room 153 Sink	0.5	4/28/2018
Frontier Valley Elementary School	Lobby Fountain	0.3	4/28/2018