

## Franktown Elementary School

- 45 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Franktown Elementary School	180210001-166 Room 47 Sink Faucet	9.4	2/10/2018
Franktown Elementary School	180210001-168 Room 44 Sink	7.8	2/10/2018
Franktown Elementary School	180210001-160 Kitchen Sink #1 Prep	4.1	2/10/2018
Franktown Elementary School	180210001-167 Room 47 Sink Drinking Fountain	3.8	2/10/2018
Franktown Elementary School	180210001-198 Room 29 Sink Faucet	3.2	2/10/2018
Franktown Elementary School	180210001-174 Room 36 Sink Drinking Fountain	2.9	2/10/2018
Franktown Elementary School	180210001-187 Room 26 Sink Faucet	2.9	2/10/2018
Franktown Elementary School	1802100-206 Room 23 Faucet	2.9	2/15/2018
Franktown Elementary School	1802100-209 Room 22 Drinking Fountain	2.5	2/15/2018
Franktown Elementary School	180210001-162 Kitchen Sink #3	2.4	2/10/2018
Franktown Elementary School	180210001-175 Room 35 Sink Faucet	2.4	2/10/2018
Franktown Elementary School	180210001-161 Kitchen Sink #2 Hand	2.3	2/10/2018
Franktown Elementary School	180210001-173 Room 36 Sink Faucet	2.0	2/10/2018
Franktown Elementary School	180210001-194 Hall Upper Drinking Fountain by Room 27	2.0	2/10/2018
Franktown Elementary School	180210001-199 Room 29 Sink Drinking Fountain	2.0	2/10/2018
Franktown Elementary School	1802100-210 Room 21 Faucet	1.8	2/15/2018
Franktown Elementary School	180210001-191 Room 25 Sink Drinking Fountain	1.7	2/10/2018
Franktown Elementary School	1802100-207 Room 23 Drinking Fountain	1.7	2/15/2018
Franktown Elementary School	180210001-163 Kitchen Sink #4	1.6	2/10/2018
Franktown Elementary School	180210001-190 Room 25 Sink Faucet	1.5	2/10/2018
Franktown Elementary School	180210001-197 Room 30 Sink Drinking Fountain	1.5	2/10/2018
Franktown Elementary School	180210001-181 Room 34 Sink Faucet	1.4	2/10/2018
Franktown Elementary School	180210001-186 Room 32 Sink Drinking Fountain	1.4	2/10/2018
Franktown Elementary School	180210001-183 Room 33 Sink Faucet	1.2	2/10/2018
Franktown Elementary School	180210001-184 Room 33 Sink Drinking Fountain	1.2	2/10/2018
Franktown Elementary School	1802100-208 Room 22 Faucet	1.2	2/15/2018
Franktown Elementary School	180210001-172 Room 37 Sink Drinking Fountain	1.1	2/10/2018
Franktown Elementary School	180210001-182 Room 34 Sink Drinking Fountain	1.1	2/10/2018

Franktown Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Franktown Elementary School	180210001-185 Room 32 Sink Faucet	1.1	2/10/2018
Franktown Elementary School	180210001-192 Room 24 Sink Faucet	1.1	2/10/2018
Franktown Elementary School	180210001-193 Room 24 Sink Drinking Fountain	1.1	2/10/2018
Franktown Elementary School	180210001-171 Room 37 Sink Faucet	0.9	2/10/2018
Franktown Elementary School	180210001-176 Room 35 Sink Drinking Fountain	0.9	2/10/2018
Franktown Elementary School	180210001-169 Room 46 Sink Faucet	0.8	2/10/2018
Franktown Elementary School	180210001-188 Room 26 Sink Drinking Fountain	0.8	2/10/2018
Franktown Elementary School	180210001-180 Room 38 Sink #2 Left	0.7	2/10/2018
Franktown Elementary School	180210001-164 Cafeteria Bottle Fill Station	0.5	2/10/2018
Franktown Elementary School	180210001-165 Cafeteria Drinking Fountain	0.5	2/10/2018
Franktown Elementary School	180210001-170 Room 46 Sink Drinking Fountain	0.5	2/10/2018
Franktown Elementary School	180210001-177 Hall Upper Drinking Fountain by Room 38	0.5	2/10/2018
Franktown Elementary School	180210001-178 Hall Lower Drinking Fountain by Room 38	0.5	2/10/2018
Franktown Elementary School	180210001-179 Room 38 Sink #1 Right	0.5	2/10/2018
Franktown Elementary School	180210001-195 Hall Lower Drinking Fountain by Room 27	0.5	2/10/2018
Franktown Elementary School	180210001-196 Room 30 Sink Faucet	0.5	2/10/2018
Franktown Elementary School	1802100-212 Teachers Lounge Sink	0.5	2/15/2018