

Flagstone Elementary School

- **5 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Flagstone Elementary School	CR088 Kitchen 4th Sink	1.5	3/3/2018
Flagstone Elementary School	CR090 207 Sink	0.5	3/3/2018
Flagstone Elementary School	CR089 213 Sink	0.3	3/3/2018
Flagstone Elementary School	CR086 Bottle Filler in Lobby	0.2	3/3/2018
Flagstone Elementary School	CR087 Fountain in Gym	0.2	3/3/2018