

Coyote Creek Elementary School

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Coyote Creek Elementary School	HR099 Kitchen 4th Sink	1.4	2/26/2018
Coyote Creek Elementary School	HR100 Rm 203 Sink	0.7	2/26/2018
Coyote Creek Elementary School	HR097 Bottle Filler Next to Office	0.3	2/26/2018
Coyote Creek Elementary School	HR098 Gym Fountain	0.3	2/26/2018