

Copper Mesa Elementary School

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Copper Mesa Elementary School	HR 344 Kitchen 2nd Sink	2.8	3/10/2018
Copper Mesa Elementary School	HR 342 Fountain next to M58	0.4	3/10/2018
Copper Mesa Elementary School	HR 343 Lower Fountain by Gym	0.4	3/10/2018
Copper Mesa Elementary School	HR 345 U15 Sink	0.4	3/10/2018