

Shea Stadium

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Shea Stadium	HR 348 North Concession Prep Sink	1.8	3/10/2018
Shea Stadium	HR 347 Prep Sink in South	0.6	3/10/2018
Shea Stadium	HR 346 Fountain Next to Ladies BR	0.4	3/10/2018