

Castle Rock Middle School

- **8 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Castle Rock Middle School	CR065 A102 4th Sink	9.7	3/3/2018
Castle Rock Middle School	CR067 Kitchen 3rd Sink	3.0	3/3/2018
Castle Rock Middle School	CR066 Left Fountain in Gym	0.2	3/3/2018
Castle Rock Middle School	CR068 D203 1st Sink	0.2	3/3/2018
Castle Rock Middle School	CR070 A206 5th Sink	0.2	3/3/2018
Castle Rock Middle School	CR064 0113 Sink	0.1	3/3/2018
Castle Rock Middle School	CR069 Fountain Across from B205	0.1	3/3/2018
Castle Rock Middle School	CR071 Fountain Next to C 126	0.1	3/3/2018