## Bear Canyon Elementary School

## Bear Canyon Elementary School

- 5 drinking water fixtures tested
- All results less than 15 ppb no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Bear Canyon Elementary School	HR082 Kitchen 1st Sink	2.0	2/24/2018
Bear Canyon Elementary School	HR084 Rm 326 Sink	1.9	2/24/2018
Bear Canyon Elementary School	HR085 Fountain Next to Sink	0.5	2/24/2018
Bear Canyon Elementary School	HR081 Bottle Filler Next to Rm 229	0.1	2/24/2018
Bear Canyon Elementary School	HR083 Gym Upper Fountain	0.1	2/24/2018