

South Ridge Elementary School

- **53 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
South Ridge Elementary School	CR373 Rm 230 Sink	12.1	4/14/2018
South Ridge Elementary School	CR333 Kitchen 5th Sink	10.7	4/14/2018
South Ridge Elementary School	CR336 Work Room Bubbler	8.3	4/14/2018
South Ridge Elementary School	CR337 Rm 570 Sink	7.6	4/14/2018
South Ridge Elementary School	CR346 Rm 540 Sink	7.4	4/14/2018
South Ridge Elementary School	CR350 Rm 520 Sink	7.0	4/14/2018
South Ridge Elementary School	CR340 Rm 550 Sink	6.6	4/14/2018
South Ridge Elementary School	CR356 Rm 310 Bubbler	5.3	4/14/2018
South Ridge Elementary School	CR329 Kitchen 1st Sink	5.1	4/14/2018
South Ridge Elementary School	CR355 Rm 310 Sink	5.1	4/14/2018
South Ridge Elementary School	CR361 Rm 350 Sink	5.0	4/14/2018
South Ridge Elementary School	CR362 Rm 360 Sink	4.9	4/14/2018
South Ridge Elementary School	CR341 Rm 550 Bubbler	3.9	4/14/2018
South Ridge Elementary School	CR374 Rm 220 Sink	3.7	4/14/2018

South Ridge Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
South Ridge Elementary School	CR376 Rm 210 Sink	3.7	4/14/2018
South Ridge Elementary School	CR377 Rm 210 Bubbler	3.6	4/14/2018
South Ridge Elementary School	CR368 Rm 250 Sink	3.2	4/14/2018
South Ridge Elementary School	CR359 Rm 340 Sink	2.7	4/14/2018
South Ridge Elementary School	CR354 Rm 320 Bubbler	2.2	4/14/2018
South Ridge Elementary School	CR332 Kitchen 4th Sink	2.1	4/14/2018
South Ridge Elementary School	CR366 Rm 260 Sink	2.1	4/14/2018
South Ridge Elementary School	CR358 Rm 330 Bubbler	2.0	4/14/2018
South Ridge Elementary School	CR348 Rm 530 Sink	1.7	4/14/2018
South Ridge Elementary School	CR349 Rm 530 Bubbler	1.7	4/14/2018
South Ridge Elementary School	CR351 Rm 520 Bubbler	1.7	4/14/2018
South Ridge Elementary School	CR353 Rm 320 Sink	1.6	4/14/2018
South Ridge Elementary School	CR338 Rm 570 Bubbler	1.5	4/14/2018
South Ridge Elementary School	CR330 Kitchen 2nd Sink	1.4	4/14/2018
South Ridge Elementary School	CR347 Rm 540 Bubbler	1.4	4/14/2018
South Ridge Elementary School	CR375 Rm 220 Bubbler	1.4	4/14/2018
South Ridge Elementary School	CR328 Cafeteria Drinking Fountain	1.3	4/14/2018

South Ridge Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
South Ridge Elementary School	CR372 Rm 240 Bubblers	1.3	4/14/2018
South Ridge Elementary School	CR331 Kitchen 3rd Sink	1.0	4/14/2018
South Ridge Elementary School	CR357 Rm 330 Sink	1.0	4/14/2018
South Ridge Elementary School	CR339 Rm 560 Sink	0.9	4/14/2018
South Ridge Elementary School	CR371 Rm 240 Sink	0.9	4/14/2018
South Ridge Elementary School	CR343 Rm 620 Sink	0.8	4/14/2018
South Ridge Elementary School	CR363 Rm 360 Bubblers	0.8	4/14/2018
South Ridge Elementary School	CR367 Rm 260 Bubblers	0.8	4/14/2018
South Ridge Elementary School	CR369 Rm 250 Bubblers	0.8	4/14/2018
South Ridge Elementary School	CR370 Teachers Lounge Sink	0.8	4/14/2018
South Ridge Elementary School	CR345 Rm 610 Sink	0.7	4/14/2018
South Ridge Elementary School	CR335 Work Room Sink	0.6	4/14/2018
South Ridge Elementary School	CR360 Rm 340 Bubblers	0.6	4/14/2018
South Ridge Elementary School	CR327 Fountain Next to Gym	0.5	4/14/2018
South Ridge Elementary School	CR334 Health Rm Sink	0.4	4/14/2018
South Ridge Elementary School	CR342 Rm 620 Drinking Fountain	0.1	4/14/2018
South Ridge Elementary School	CR344 Rm 610 Drinking Fountain	0.1	4/14/2018

South Ridge Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
South Ridge Elementary School	CR352 Drinkign Fountain Next to 510	0.1	4/14/2018
South Ridge Elementary School	CR364 Upper Fountain Next to Custodial Office	0.1	4/14/2018
South Ridge Elementary School	CR365 Lower Fountain Next to Custodial Office	0.1	4/14/2018
South Ridge Elementary School	CR378 Bottle Filler in Lobby	0.1	4/14/2018
South Ridge Elementary School	CR379 Drinking Fountain in Lobby	0.1	4/14/2018