

Pine Grove Elementary School

- 4 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Pine Grove Elementary School	Kitchen Sink 1	4.6	4/10/2018
Pine Grove Elementary School	Room 202	1.0	4/10/2018
Pine Grove Elementary School	Gym Drinking Fountain	0.3	4/10/2018
Pine Grove Elementary School	Lobby Drinking Fountain	0.2	4/10/2018