

O & M East Building

- **6 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
O & M East Building	1802100-201 Shop Water Fountain	0.7	2/15/2018
O & M East Building	1802100-200 Main Hallway Drinking Fountain	0.5	2/15/2018
O & M East Building	1802100-202 Shop Bottle Filler	0.5	2/15/2018
O & M East Building	1802100-203 Break Room Sink	0.5	2/15/2018
O & M East Building	1802100-204 Coffee Machine	0.5	2/15/2018
O & M East Building	1802100-205 Cold Water Chiller	0.5	2/15/2018