

Northeast Elementary School

- **37 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Northeast Elementary School	180210001-16 Room 128 Sink	2.6	2/10/2018
Northeast Elementary School	180210001-35 Art Room First Sink	2.0	2/10/2018
Northeast Elementary School	180210001-41 Kitchen Sink #1	1.9	2/10/2018
Northeast Elementary School	180210001-20 Room 155 Sink	1.8	2/10/2018
Northeast Elementary School	180210001-44 Kitchen Wash Sink #4	1.6	2/10/2018
Northeast Elementary School	180210001-17 Room 121 Sink	1.3	2/10/2018
Northeast Elementary School	180210001-22 Room 152 Sink	1.3	2/10/2018
Northeast Elementary School	180210001-15 Room 143 Sink	1.2	2/10/2018
Northeast Elementary School	180210001-23 Room 153 Sink	1.2	2/10/2018
Northeast Elementary School	180210001-18 Room 141 Sink	1.1	2/10/2018
Northeast Elementary School	180210001-43 Kitchen Wash Sink #3	0.9	2/10/2018
Northeast Elementary School	180210001-21 Room 154 Sink	0.9	2/10/2018
Northeast Elementary School	180210001-14 Room 142 Sink	0.9	2/10/2018
Northeast Elementary School	180210001-42 Kitchen Sink #2	0.9	2/10/2018
Northeast Elementary School	180210001-32 Room 160 Sink	0.7	2/10/2018
Northeast Elementary School	180210001-37 Gym Fountain	0.6	2/10/2018
Northeast Elementary School	180210001-19 Room 145 Sink	0.6	2/10/2018
Northeast Elementary School	180210001-36 Art Room Second Sink	0.6	2/10/2018
Northeast Elementary School	180210001-11 Room 141 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-09 Room 140 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-10 Hall Fountain by Room 140	0.5	2/10/2018
Northeast Elementary School	180210001-12 Room 105 Sink Between Bathrooms	0.5	2/10/2018
Northeast Elementary School	180210001-13 Room 106 Teachers Lounge Kitchen Sink	0.5	2/10/2018
Northeast Elementary School	180210001-24 Room 150 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-25 Room 151 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-26 Room 166 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-27 Room 165 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-28 Hall Fountain by Room 117	0.5	2/10/2018

Northeast Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Northeast Elementary School	180210001-29 Room 163 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-30 Room 162 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-31 Room 161 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-33 Hall Fountain by Room 263	0.5	2/10/2018
Northeast Elementary School	180210001-34 Room 263 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-38 Room 252 Sink	0.5	2/10/2018
Northeast Elementary School	180210001-39 Cafeteria Bottle Fill Station	0.5	2/10/2018
Northeast Elementary School	180210001-40 Cafeteria Bottle Fill Fountain	0.5	2/10/2018
Northeast Elementary School	180210001-45 Hall Fountain By Room 221	0.5	2/10/2018