

North Transportation Building

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
North Transportation Building	180210001-125 O & M Sink	2.2	2/10/2018
North Transportation Building	180210001-124 Kitchen Sink	2.1	2/10/2018
North Transportation Building	180210001-126 O & M Water Cooler	0.5	2/10/2018