

**Mountain Vista High School**

- 10 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain Vista High School	HR 350 Kitchen 7th Sink	1.0	3/13/2018
Mountain Vista High School	HR 354 V427 Sink	0.6	3/13/2018
Mountain Vista High School	HR 351 Athletic Hall Fountain	0.5	3/13/2018
Mountain Vista High School	HR 352 L527 Sink	0.5	3/13/2018
Mountain Vista High School	HR 355 V301 4th Sink	0.5	3/13/2018
Mountain Vista High School	HR 356 Fountain Next to V303	0.5	3/13/2018
Mountain Vista High School	HR 349 Staff Lounge Sink	0.4	3/13/2018
Mountain Vista High School	HR 353 Fountain Next to L419	0.4	3/13/2018
Mountain Vista High School	HR 357 V327 Sink	0.3	3/13/2018
Mountain Vista High School	HR 358 Fountain in Lobby	0.2	3/13/2018