

Mountain View Elementary School

- **64 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain View Elementary School	180210001-72 Room 3A Sink	8.2	2/10/2018
Mountain View Elementary School	180210001-91 Room 8 Sink Faucet	4.9	2/10/2018
Mountain View Elementary School	180210001-92 Room 8 Sink Drinking Fountain	2.8	2/10/2018
Mountain View Elementary School	180210001-65 Room 6A2 Sink	2.7	2/10/2018
Mountain View Elementary School	180210001-103 Room 1A Sink	2.6	2/10/2018
Mountain View Elementary School	180210001-61 Room 19 Sink Faucet	2.3	2/10/2018
Mountain View Elementary School	180210001-76 Room 13 Sink Faucet	1.7	2/10/2018
Mountain View Elementary School	180210001-64 Room 18 Sink Drinking Fountain	1.2	2/10/2018
Mountain View Elementary School	180210001-86 Room 2A Sink	1.1	2/10/2018
Mountain View Elementary School	180210001-74 Room 14 Sink Faucet	1.0	2/10/2018
Mountain View Elementary School	180210001-73 Room 15 Sink Faucet	1.0	2/10/2018
Mountain View Elementary School	180210001-80 Room 11 Sink Faucet	1.0	2/10/2018
Mountain View Elementary School	180210001-81 Room 11 Sink Drinking Fountain	0.8	2/10/2018
Mountain View Elementary School	180210001-89 Room 9 Sink Faucet	0.7	2/10/2018

Mountain View Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain View Elementary School	180210001-66 Room 23 Sink Faucet	0.7	2/10/2018
Mountain View Elementary School	180210001-109 Room 1 Sink Drinking Fountain	0.6	2/10/2018
Mountain View Elementary School	180210001-100 Room 4 Sink Drinking Fountain	0.6	2/10/2018
Mountain View Elementary School	180210001-68 Room 17 Sink Faucet	0.6	2/10/2018
Mountain View Elementary School	180210001-106 Room 2 Sink Faucet	0.6	2/10/2018
Mountain View Elementary School	180210001-88 Room 25 Left Sink Two	0.6	2/10/2018
Mountain View Elementary School	180210001-77 Room 13 Sink Drinking Fountain	0.6	2/10/2018
Mountain View Elementary School	180210001-62 Room 19 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-82 Room 10 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-54 Room 24 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-101 Hall Fountain Upper by 1A	0.5	2/10/2018
Mountain View Elementary School	180210001-102 Hall Lower Fountain by 1A	0.5	2/10/2018
Mountain View Elementary School	180210001-104 Room 3 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-105 Room 3 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-107- Room 2 Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-108 Room 1 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-46 Teachers Lounge Kitchen Sink	0.5	2/10/2018

Mountain View Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain View Elementary School	180210001-47 Teachers Lounge Water Cooler	0.5	2/10/2018
Mountain View Elementary School	180210001-48 Teachers Lounge Refrigerator	0.5	2/10/2018
Mountain View Elementary School	180210001-49 Cafeteria Bottle Fill Station	0.5	2/10/2018
Mountain View Elementary School	180210001-50 Cafeteria Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-51 Kitchen Sink #1 Food Prep	0.5	2/10/2018
Mountain View Elementary School	180210001-52 Kitchen Sink #2	0.5	2/10/2018
Mountain View Elementary School	180210001-53 Kitchen Sink #3	0.5	2/10/2018
Mountain View Elementary School	180210001-55 Room 24 Sink Drinking Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-56 Room 21 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-57 Room 21 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-58 Room 20 Sink	0.5	2/10/2018
Mountain View Elementary School	180210001-59 Hall Upper Fountain by 4C	0.5	2/10/2018
Mountain View Elementary School	180210001-60 Hall Lower Fountain by 4C	0.5	2/10/2018
Mountain View Elementary School	180210001-63 Room 18 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-67 Room 23 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-69 Room 17 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-70 Room 16 Sink Faucet	0.5	2/10/2018

Mountain View Elementary School

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain View Elementary School	180210001-71 Room 16 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-75 Room 14 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-78 Room 12 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-79 Room 12 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-83 Room 10 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-84 Hall Fountain Upper by 2A	0.5	2/10/2018
Mountain View Elementary School	180210001-85 Hall Fountain Lower by 2A	0.5	2/10/2018
Mountain View Elementary School	180210001-87 Room 25 Right Sink One	0.5	2/10/2018
Mountain View Elementary School	180210001-90 Room 9 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-93 Room 7 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-94 Room 7 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-95 Room 6 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-96 Room 6 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-97 Room 5 Sink Faucet	0.5	2/10/2018
Mountain View Elementary School	180210001-98 Room 5 Sink Drinking Fountain	0.5	2/10/2018
Mountain View Elementary School	180210001-99 Room 4 Sink Faucet	0.5	2/10/2018