

Mountain Ridge Middle School

- **8 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mountain Ridge Middle School	HR002 Kitchen 4th Sink	3.4	2/24/2018
Mountain Ridge Middle School	HR001 Rm 174, Sink	1.1	2/24/2018
Mountain Ridge Middle School	HR004 Rm 120 3rd Sink	0.7	2/24/2018
Mountain Ridge Middle School	HR005 Rm 274 3rd Sink	0.7	2/24/2018
Mountain Ridge Middle School	HR007 Rm 240 4th Sink	0.7	2/24/2018
Mountain Ridge Middle School	HR006 Fountain Next to 253	0.2	2/24/2018
Mountain Ridge Middle School	HR003 Fountain Next to 152	0.1	2/24/2018
Mountain Ridge Middle School	HR008 Fountain Next to Band	0.1	2/24/2018