

Mesa Middle School

- 7 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Mesa Middle School	CR001 B104 2nd Sink	2.7	3/3/2018
Mesa Middle School	CR002 D104 4th Sink	2.0	3/3/2018
Mesa Middle School	CR003 Kitchen 4th Sink	1.7	3/3/2018
Mesa Middle School	CR005 A204 1st Sink	1.3	3/3/2018
Mesa Middle School	CR007 Fountain Next to Gym	0.3	3/3/2018
Mesa Middle School	CR004 Bottle Filler Next to M204	0.2	3/3/2018
Mesa Middle School	CR006 Fountain Across from C206	0.1	3/3/2018