

Legend High School

- 13 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Legend High School	F101 Prep	10.3	4/28/2018
Legend High School	D101 3rd Sink	2.2	4/28/2018
Legend High School	F201 4th Sink	1.3	4/28/2018
Legend High School	Kitchen 7th Sink	1.2	4/28/2018
Legend High School	A202 Sink	1.1	4/28/2018
Legend High School	F113 Sink	0.9	4/28/2018
Legend High School	A204 Wrestling Room Fountain	0.9	4/28/2018
Legend High School	E200 Teachers' Sink	0.7	4/28/2018
Legend High School	E216 4th Sink	0.7	4/28/2018
Legend High School	Fountain by D113	0.1	4/28/2018
Legend High School	Lobby Bottle Filler	0.1	4/28/2018
Legend High School	A103 Weight Room Fountain	0.1	4/28/2018
Legend High School	Fountain by F213	0.1	4/28/2018