

**Echo Park Stadium**

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Echo Park Stadium	C311	5.1	4/28/2018
Echo Park Stadium	Press Box Sink	3.4	4/28/2018
Echo Park Stadium	Incoming Service Line	0.9	4/28/2018