

DC OAKES-DLMC

- **3 drinking water fixtures tested**
- **All results less than 15 ppb - no further action needed**

Site	Sample ID	Initial Result (ppb)	1st Collection Date
DC OAKES-DLMC	CR084 Sink Near Front Door DLMC	0.6	3/3/2018
DC OAKES-DLMC	CR085 DLMC Lounge	0.6	3/3/2018
DC OAKES-DLMC	CR083 Bottle Filler in Lobby	0.1	3/3/2018