

## Cresthill Middle School

- 13 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Cresthill Middle School	HR059 Rm 1156 2nd Sink	3.5	2/24/2018
Cresthill Middle School	HR063 2158 2nd Sink	2.5	2/24/2018
Cresthill Middle School	HR055 Kitchen 7th Sink	2.3	2/24/2018
Cresthill Middle School	HR053 Rm 1184 Sink	1.9	2/24/2018
Cresthill Middle School	HR054 Rm 1199 Sink	1.1	2/24/2018
Cresthill Middle School	HR058 1159 3rd Sink	0.6	2/24/2018
Cresthill Middle School	HR057 Main Office Lounge	0.5	2/24/2018
Cresthill Middle School	HR064 1158 1st Sink	0.4	2/24/2018
Cresthill Middle School	HR052 Bottle Filler Outside Cafeteria	0.2	2/24/2018
Cresthill Middle School	HR056 Upper Fountain Next to 1232	0.2	2/24/2018
Cresthill Middle School	HR061 Lower Fountain Next to 2143	0.2	2/24/2018
Cresthill Middle School	HR062 Rm 2155 Island Sink (5th)	0.2	2/24/2018
Cresthill Middle School	HR060 Upper Fountain Next to 1143	0.1	2/24/2018