

Castle View High School

- 11 drinking water fixtures tested
- All results less than 15 ppb - no further action needed

Site	Sample ID	Initial Result (ppb)	1st Collection Date
Castle View High School	CR022 5200 4th Sink	1.8	3/3/2018
Castle View High School	CR015 Kitchen 7th Sink	0.7	3/3/2018
Castle View High School	CR014 Bottle Filler in Lobby	0.1	3/3/2018
Castle View High School	CR016 Lower Fountain Next to 6300	0.1	3/3/2018
Castle View High School	CR017 8025 Sink	0.1	3/3/2018
Castle View High School	CR018 8200 3rd Sink	0.1	3/3/2018
Castle View High School	CR019 Fountain Next to Rm 9025	0.1	3/3/2018
Castle View High School	CR020 9100 2nd Sink	0.1	3/3/2018
Castle View High School	CR021 5025 Sink	0.1	3/3/2018
Castle View High School	CR023 Fountain Next to Sink	0.1	3/3/2018
Castle View High School	CR024 2200 Kitchen Sink	0.1	3/3/2018